



108 MILE WATER SYSTEM 2025 ANNUAL REPORT

Operating Permit # 2952

CRD Utilities Department

building communities together

File: 5600-20-06-01

January 14, 2026

Diana Tesic-Nagalingam
Environmental Health Officer
Interior Health
Kamloops Health Centre
519 Columbia Street
Kamloops, BC V2C 2T8

Dear Diana Tesic-Nagalingam:

Re: Transmittal of the 2025 Annual Report for the 108 Mile Water System

We are pleased to submit the 2025 Annual Report for the 108 Mile Water System. This report is prepared to provide a comprehensive summary of the key developments, activities, and achievements of 2025, as well as to outline plans for the water system.

The report has been developed with consideration for public engagement and transparency, ensuring it meets the information needs of Interior Health, the Cariboo Regional District Board of Directors, and particularly the 108 Mile community, as represented by Electoral Area G Director Al Richmond.

We trust this report will serve as a valuable resource in understanding the progress and direction of the 108 Mile Water System.

Sincerely,

Kelly McDonald
Manager of Utilities

KM/cm

building communities together

Contents

Executive Summary	1
Highlights	1
1. Introduction	1
2. Maintenance and Operational Work (2025)	2
<i>2.1. Completed Activities</i>	<i>2</i>
3. Water Treatment, Pressure Zones, and System Configuration	2
4. Water Demand (2025)	2
5. Water Quality, Advisories, and Monitoring	3
6. Looking Ahead: 2026 Priorities.....	3
7. Conclusion.....	4
Appendix A: Links	5
Appendix B: Sample Results	7
Appendix C: Cariboo Regional District Water System Statistics	16
Appendix D: Emergency Response Plan	19

Tables and Figures

Figure 1: 108 Mile Water System – Monthly Water Demand (2025)	3
---	---

Executive Summary

In 2025, the 108 Mile Water System, the largest water system operated by the Cariboo Regional District with over 1,400 individual service connections, continued to deliver potable water while managing a complex and high-maintenance distribution network. The system supplied a total of 363,369 cubic metres of water during the year, with the highest demand occurring in September and the lowest demand in February. Estimated per capita water use was 289.5 litres per person per day, consistent with large residential systems.

The system utilizes a biological water treatment plant designed to remove elevated manganese concentrations. Operation of this facility, along with the broader system, requires skilled and certified operators due to its complexity and ongoing maintenance demands. The water system was inherited by CRD from a private subdivision developer and was not constructed to municipal standards, resulting in operational challenges including undersized mains, numerous dead-end lines, and extensive use of thin-wall irrigation pipe.

Two precautionary Boil Water Advisories were issued in 2025 following pressure losses caused by breaks. Both advisories were lifted once system pressures were restored and water quality conditions stabilized. To address persistent low-pressure concerns, particularly within one of the system's two pressure zones, CRD advanced planning for a second booster station, with construction scheduled to begin in early 2026.

Highlights

- Largest CRD Water System: Serving over 1,400 service connections
- Biological Treatment in Operation: Effectively removes elevated manganese
- Two Precautionary Boil Water Advisories: Issued and lifted following pressure losses from breaks
- Booster Station Tendered: Second booster planned to improve system pressures
- Comprehensive Maintenance Undertaken: Hydrants, valves, fittings, and treatment plant upgrades
- Asset Preparedness Improved: Inventory of fittings established to support timely leak repairs

1. Introduction

The 108 Mile Water System serves the 108 Mile Ranch community and is owned and operated by the Cariboo Regional District. It is the largest water system in CRD's portfolio and consists of two independent pressure zones, one of which is supplemented by a booster station to maintain adequate service pressures.

The system includes a biological water treatment plant that removes naturally occurring manganese from the source water. While effective, the treatment process and distribution

network require a higher level of operational oversight and maintenance due to system complexity and infrastructure limitations inherited from its original construction.

2. Maintenance and Operational Work (2025)

2.1. Completed Activities

- ✓ Valve Maintenance Program Initiated: Improving system operability and isolation capability
- ✓ Fire Hydrant Maintenance: 65 hydrants inspected and fully serviced (tear-downs completed)
- ✓ Fittings Inventory Established: Supporting faster and more reliable leak repairs
- ✓ Business Plan Development Began: Addressing future development and system sustainability
- ✓ Water Treatment Plant PLC Upgrade: Improving control and operational reliability
- ✓ Concrete Loading Pad Installed: Protecting overhead infrastructure from vehicle impacts
- ✓ Air Compressor Serviced: Maintaining treatment plant reliability
- ✓ Fire Extinguishers Replaced: Updated safety equipment across facilities

Distribution system repairs completed in 2025 included:

- ✓ 1 main break repair
- ✓ 1 blow-off repair
- ✓ 1 hydrant valve repair
- ✓ 12+ service connection repairs

3. Water Treatment, Pressure Zones, and System Configuration

The 108 Mile Water System utilizes a biological treatment process to remove elevated manganese, ensuring treated water meets applicable water quality standards. Operation of this facility requires skilled operators and regular maintenance.

The system is configured into two independent pressure zones, one of which is augmented by a booster station. Due to persistent low-pressure challenges in certain areas—largely attributable to legacy infrastructure design—a second booster station was tendered in 2025 and is scheduled for construction in early 2026.

4. Water Demand (2025)

Metric Value:

- Total Annual Use: 363,369 m³
- Pumped from Telqua Reservoir: 73,841 m³
- Pumped from Kylo Reservoirs: 286,883 m³

- Peak Use Month: September – 45,539 m³
- Lowest Use Month: February – 20,637 m³
- Estimated Per Capita Use: 289.5 litres/person/day

The remaining volume was supplied directly from the distribution system to service connections. Demand patterns reflect typical seasonal residential use in a large rural system.




Figure 1: 108 Mile Water System – Monthly Water Demand (2025)

5. Water Quality, Advisories, and Monitoring

The 108 Mile Water System met drinking water quality requirements throughout 2025, with manganese effectively managed through biological treatment.

- ✓ Biological treatment plant maintained effective manganese removal
- ✓ Two precautionary Boil Water Advisories issued due to pressure losses from main breaks
- ✓ Both advisories lifted once pressures were restored and system stability confirmed
- ✓ Continuous operational monitoring and operator oversight maintained system performance
- ✓ Extensive sampling schedule both laboratory and by staff to meet or exceed Interior Health standards

6. Looking Ahead: 2026 Priorities

- Construct Second Booster Station: Improving pressure reliability in low-pressure areas

- Continue Valve Maintenance Program: Expanding system isolation capability
- Advance Business Planning: Supporting long-term development and infrastructure renewal
- Ongoing Treatment Plant Optimization: Maintaining reliable manganese removal
- Targeted Infrastructure Improvements: Addressing risks associated with legacy system design

7. Conclusion

In 2025, the 108 Mile Water System continued to deliver potable water to a large and growing customer base while managing significant operational complexity associated with legacy infrastructure. Proactive maintenance, treatment plant upgrades, and preparation for pressure improvements demonstrate CRD's commitment to system reliability and public health. With construction of a second booster station planned for 2026 and continued focus on asset management and planning, the system is positioned to progressively address inherited challenges and improve service resilience over the long term.

Thank you to:

- | | |
|--------------------|-----------------|
| • Cheryl McMullen | • Phil Wilkins |
| • Jourdy Ouellette | • Tyler Olsen |
| • Larry Perry | • Ken Heidema |
| • Colin Brusic | • Charles Howes |

for their contribution.

Appendix A: Links

Interior Health:

- [*Interior Health Water Advisories*](#)
- [*Drinking Water | Environmental & Seasonal Health | IH*](#)

Cariboo Regional District:

- [*Water Notices and Advisories - Cariboo Regional District*](#)
- [*Sewer and Water Services - Cariboo Regional District*](#)

Notification App (VoyentAlert!):

- [*Emergency Notification System - Cariboo Regional District*](#)

Environmental Operators Certification Program (EOCP):

- [*EOCP Homepage | EOCP*](#)
- [*Backflow Prevention, Cross Connection Control, and the Environmental Operators Certification Program | EOCP*](#)

Appendix B: Sample Results

2025 108 Mile Water System Annual Report

Facility and Sample Site: 108 Mile Water System 108 Mile Ranch, BC	Test Type: Drinking Water – Bacteriological Unit of Measure: CFU per 100 ml	Value	Date Collected	Results
Sepa Well 3	Sample Parameter: E. coli	<1	15 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	15 Jan 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	15 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	15 Jan 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	15 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	15 Jan 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	15 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	15 Jan 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	22 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Jan 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	22 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Jan 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	22 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Jan 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	22 Jan 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Jan 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	11 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Feb 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	11 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Feb 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	11 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Feb 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	25 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Feb 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	25 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Feb 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	25 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Feb 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	25 Feb 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Feb 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	11 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Mar 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	11 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Mar 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	11 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Mar 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	11 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	11 Mar 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	26 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Mar 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	26 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Mar 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	26 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Mar 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	26 Mar 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Mar 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	08 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Apr 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	08 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Apr 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	08 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Apr 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	08 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Apr 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	29 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	29 Apr 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	29 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	29 Apr 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	29 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	29 Apr 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	29 Apr 2025	Acceptable
	Sample Parameter: Total Coliform	<1	29 Apr 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	13 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	13 May 2025	Acceptable

2025 108 Mile Water System Annual Report

Facility and Sample Site: 108 Mile Water System 108 Mile Ranch, BC	Test Type: Drinking Water – Bacteriological Unit of Measure: CFU per 100 ml	Value	Date Collected	Results
108 Water Treatment Plant	Sample Parameter: E. coli	<1	13 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	13 May 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	13 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	13 May 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	13 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	13 May 2025	Acceptable
Canium Court	Sample Parameter: E. coli	<1	14 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	14 May 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	21 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	21 May 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	21 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	21 May 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	21 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	21 May 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	21 May 2025	Acceptable
	Sample Parameter: Total Coliform	<1	21 May 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	04 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Jun 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	04 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Jun 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	04 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Jun 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	04 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Jun 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	24 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	24 Jun 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	24 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	24 Jun 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	24 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	24 Jun 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	24 Jun 2025	Acceptable
	Sample Parameter: Total Coliform	<1	24 Jun 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	16 Jul 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Jul 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	16 Jul 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Jul 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	16 Jul 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Jul 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	16 Jul 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Jul 2025	Acceptable
Gloinnzun Drive	Sample Parameter: E. coli	<1	16 Jul 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Jul 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	26 Aug 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Aug 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	26 Aug 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Aug 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	26 Aug 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Aug 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	26 Aug 2025	Acceptable
	Sample Parameter: Total Coliform	<1	26 Aug 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	09 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	09 Sep 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	09 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	09 Sep 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	09 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	09 Sep 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	09 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	09 Sep 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	23 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	23 Sep 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	23 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	23 Sep 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	23 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	23 Sep 2025	Acceptable

2025 108 Mile Water System Annual Report

Facility and Sample Site: 108 Mile Water System 108 Mile Ranch, BC	Test Type: Drinking Water – Bacteriological Unit of Measure: CFU per 100 ml	Value	Date Collected	Results
108 Mall Sample Station	Sample Parameter: E. coli	<1	23 Sep 2025	Acceptable
	Sample Parameter: Total Coliform	<1	23 Sep 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	08 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Oct 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	08 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Oct 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	08 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Oct 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	08 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	08 Oct 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	22 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Oct 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	22 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Oct 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	22 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Oct 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	22 Oct 2025	Acceptable
	Sample Parameter: Total Coliform	<1	22 Oct 2025	Acceptable
Sepa Well 3	Sample Parameter: E. coli	<1	04 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Nov 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	04 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Nov 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	04 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Nov 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	04 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	04 Nov 2025	Acceptable
Sepa Well (Raw)	Sample Parameter: E. coli	<1	19 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	19 Nov 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	19 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	19 Nov 2025	Acceptable
Church	Sample Parameter: E. coli	<1	19 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	19 Nov 2025	Acceptable
Sepa Well (Raw)	Sample Parameter: E. coli	<1	25 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Nov 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	25 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Nov 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	25 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Nov 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	25 Nov 2025	Acceptable
	Sample Parameter: Total Coliform	<1	25 Nov 2025	Acceptable
Sepa Well (Raw)	Sample Parameter: E. coli	<1	02 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	02 Dec 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	02 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	02 Dec 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	02 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	02 Dec 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	02 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	02 Dec 2025	Acceptable
Sepa Well (Raw)	Sample Parameter: E. coli	<1	16 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Dec 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: E. coli	<1	16 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Dec 2025	Acceptable
Kyllo Road Sample Station	Sample Parameter: E. coli	<1	16 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Dec 2025	Acceptable
108 Mall Sample Station	Sample Parameter: E. coli	<1	16 Dec 2025	Acceptable
	Sample Parameter: Total Coliform	<1	16 Dec 2025	Acceptable

2025 108 Mile Water System Annual Report

Facility and Sample Site: 108 Mile Water System 108 Mile Ranch, BC	Test Type: Drinking Water – Metals Unit of Measure: mg/L	Value	MAC	Date Collected	Results
108 Water Treatment Plant	Sample Parameter: Manganese	0.00076 ^{RRV}	0.12 mg/L	16 Jul 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00019	0.12 mg/L	26 Aug 2025	Acceptable
Kyllo Road	Sample Parameter: Manganese	0.967	0.12 mg/L	26 Aug 2025	Unacceptable
Kyllo Road Blowoff	Sample Parameter: Manganese	0.0889	0.12 mg/L	09 Sep 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00322	0.12 mg/L	23 Sep 2025	Acceptable
108 Water Treatment Plant (Tap)	Sample Parameter: Manganese	0.0391	0.12 mg/L	08 Oct 2025	Acceptable
108 Water Treatment Plant	Sample Parameter: Manganese	0.00033	0.12 mg/L	22 Oct 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00031	0.12 mg/L	04 Nov 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00022	0.12 mg/L	25 Nov 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00012	0.12 mg/L	02 Dec 2025	Acceptable
108 Water Treatment Plant (Filtered)	Sample Parameter: Manganese	0.00884	0.12 mg/L	16 Dec 2025	Acceptable
MAC = Maximum Acceptable Concentrations RRV = Reported result verified by repeat analysis					

2025 108 Mile Water System Annual Report

Work Order : KS2501226
Client : Cariboo Regional District
Project : 108 Mile Ranch



Analytical Results

Sub-Matrix: Water
(Matrix: Water)

Client sample ID					108 Mile Ranch WTP	----	----	----	----
Client sampling date / time					08-Apr-2025 11:50	----	----	----	----
Analyte	CAS Number	Method/Lab	LOR	Unit	KS2501226-001	----	----	----	----
Result					----	----	----	----	----
Physical Tests									
Absorbance, UV (@ 254nm), unfiltered	----	E405/VA	0.0050	AU/cm	0.0490	----	----	----	----
Alkalinity, bicarbonate (as CaCO ₃)	----	E290/VA	1.0	mg/L	546	----	----	----	----
Alkalinity, carbonate (as CaCO ₃)	----	E290/VA	1.0	mg/L	<1.0	----	----	----	----
Alkalinity, hydroxide (as CaCO ₃)	----	E290/VA	1.0	mg/L	<1.0	----	----	----	----
Alkalinity, phenolphthalein (as CaCO ₃)	----	E290/VA	1.0	mg/L	<1.0	----	----	----	----
Alkalinity, total (as CaCO ₃)	----	E290/VA	1.0	mg/L	546	----	----	----	----
Colour, true	----	E329/VA	5.0	CU	<5.0	----	----	----	----
Conductivity	----	E100/VA	2.0	µS/cm	1400	----	----	----	----
Hardness (as CaCO ₃), from total Ca/Mg	----	EC100A/VA	0.60	mg/L	567	----	----	----	----
Langelier index (@ 15°C)	----	EC105A/VA	0.010	-	1.08	----	----	----	----
Langelier index (@ 20°C)	----	EC105A/VA	0.010	-	1.15	----	----	----	----
Langelier index (@ 25°C)	----	EC105A/VA	0.010	-	1.22	----	----	----	----
Langelier index (@ 4°C)	----	EC105A/VA	0.010	-	0.907	----	----	----	----
Langelier index (@ 60°C)	----	EC105A/VA	0.010	-	1.66	----	----	----	----
Langelier index (@ 77°C)	----	EC105A/VA	0.010	-	1.85	----	----	----	----
pH	----	E108/VA	0.10	pH units	8.07	----	----	----	----
Solids, total dissolved [TDS]	----	E162/VA	10	mg/L	841	----	----	----	----
Turbidity	----	E121/VA	0.10	NTU	<0.10	----	----	----	----
Transmittance, UV (@ 254nm), unfiltered	----	E405/VA	1.0	% T/cm	89.3	----	----	----	----
Anions and Nutrients									
Ammonia, total (as N)	7664-41-7	E298/VA	0.0050	mg/L	0.0058	----	----	----	----

2025 108 Mile Water System Annual Report

Work Order : KS2501226
Client : Cariboo Regional District
Project : 108 Mile Ranch



Analytical Results

Sub-Matrix: Water
(Matrix: Water)

Client sample ID					108 Mile Ranch WTP	----	----	----	----
Client sampling date / time					08-Apr-2025 11:50	----	----	----	----
Analyte	CAS Number	Method/Lab	LOR	Unit	KS2501226-001	----	----	----	----
Result					Result	----	----	----	----
Anions and Nutrients									
Bromide	24959-67-9	E235.Br-L/VA	0.050	mg/L	<0.250 ^{DLOS}	----	----	----	----
Chloride	16887-00-6	E235.Cl/VA	0.50	mg/L	106	----	----	----	----
Fluoride	16984-48-8	E235.F/VA	0.020	mg/L	0.511	----	----	----	----
Kjeldahl nitrogen, total [TKN]	----	E318/VA	0.050	mg/L	0.251	----	----	----	----
Nitrate (as N)	14797-55-8	E235.NO3-L/VA	0.0050	mg/L	0.580	----	----	----	----
Nitrite (as N)	14797-65-0	E235.NO2-L/VA	0.0010	mg/L	0.0114	----	----	----	----
Nitrogen, total organic	----	EC363/VA	0.050	mg/L	0.245	----	----	----	----
Sulfate (as SO4)	14808-79-8	E235.SO4/VA	0.30	mg/L	85.6	----	----	----	----
Cyanides									
Cyanide, strong acid dissociable (Total)	----	E333/VA	0.0050	mg/L	<0.0050	----	----	----	----
Organic / Inorganic Carbon									
Carbon, total organic [TOC]	----	E355-L/VA	0.50	mg/L	5.70	----	----	----	----
Microbiological Tests									
Coliforms, total	----	E010/KS	1	MPN/100 mL	<1	----	----	----	----
Coliforms, Escherichia coli [E. coli]	----	E010/KS	1	MPN/100 mL	<1	----	----	----	----
Ion Balance									
Anion sum	----	EC101A/VA	0.10	meq/L	15.8	----	----	----	----
Cation sum (total)	----	EC101A/VA	0.10	meq/L	15.6	----	----	----	----
Ion balance (APHA)	----	EC101A/VA	0.010	%	-0.637	----	----	----	----
Total Metals									
Aluminum, total	7429-90-5	E420/VA	0.0030	mg/L	<0.0030	----	----	----	----

2025 108 Mile Water System Annual Report

Work Order : KS2501226
Client : Cariboo Regional District
Project : 108 Mile Ranch



Analytical Results

Sub-Matrix: Water
(Matrix: Water)

					Client sample ID	108 Mile Ranch WTP	---	---	---	---
					Client sampling date / time	08-Apr-2025 11:50	---	---	---	---
Analyte	CAS Number	Method/Lab	LOR	Unit	KS2501226-001	---	---	---	---	---
					Result	---	---	---	---	---
Total Metals										
Antimony, total	7440-36-0	E420/VA	0.00010	mg/L	<0.00010	---	---	---	---	---
Arsenic, total	7440-38-2	E420/VA	0.00010	mg/L	0.00166	---	---	---	---	---
Barium, total	7440-39-3	E420/VA	0.00010	mg/L	0.0110	---	---	---	---	---
Beryllium, total	7440-41-7	E420/VA	0.000100	mg/L	<0.000100	---	---	---	---	---
Bismuth, total	7440-69-9	E420/VA	0.000050	mg/L	<0.000050	---	---	---	---	---
Boron, total	7440-42-8	E420/VA	0.010	mg/L	0.083	---	---	---	---	---
Cadmium, total	7440-43-9	E420/VA	0.0000050	mg/L	<0.0000050	---	---	---	---	---
Calcium, total	7440-70-2	E420/VA	0.050	mg/L	75.8	---	---	---	---	---
Cesium, total	7440-46-2	E420/VA	0.000010	mg/L	0.000010	---	---	---	---	---
Chromium, total	7440-47-3	E420/VA	0.00050	mg/L	<0.00050	---	---	---	---	---
Cobalt, total	7440-48-4	E420/VA	0.00010	mg/L	<0.00010	---	---	---	---	---
Copper, total	7440-50-8	E420/VA	0.00050	mg/L	0.00115	---	---	---	---	---
Iron, total	7439-89-6	E420/VA	0.010	mg/L	<0.010	---	---	---	---	---
Lead, total	7439-92-1	E420/VA	0.000050	mg/L	<0.000050	---	---	---	---	---
Lithium, total	7439-93-2	E420/VA	0.0010	mg/L	0.0064	---	---	---	---	---
Magnesium, total	7439-95-4	E420/VA	0.0050	mg/L	91.8	---	---	---	---	---
Manganese, total	7439-96-5	E420/VA	0.00010	mg/L	0.00186	---	---	---	---	---
Mercury, total	7439-97-6	E508/VA	0.0000050	mg/L	0.0000083	---	---	---	---	---
Molybdenum, total	7439-98-7	E420/VA	0.000050	mg/L	0.00691	---	---	---	---	---
Nickel, total	7440-02-0	E420/VA	0.00050	mg/L	0.00094	---	---	---	---	---
Phosphorus, total	7723-14-0	E420/VA	0.050	mg/L	0.065	---	---	---	---	---

2025 108 Mile Water System Annual Report

Work Order : KS2501226
Client : Cariboo Regional District
Project : 108 Mile Ranch



Analytical Results

Sub-Matrix: Water
(Matrix: Water)

					Client sample ID	108 Mile Ranch WTP	----	----	----	----
					Client sampling date / time	08-Apr-2025 11:50	----	----	----	----
Analyte	CAS Number	Method/Lab	LOR	Unit	KS2501226-001	----	----	----	----	----
					Result	----	----	----	----	----
Total Metals										
Potassium, total	7440-09-7	E420/VA	0.050	mg/L	8.18	----	----	----	----	----
Rubidium, total	7440-17-7	E420/VA	0.00020	mg/L	0.00335	----	----	----	----	----
Selenium, total	7782-49-2	E420/VA	0.000050	mg/L	0.000123	----	----	----	----	----
Silicon, total	7440-21-3	E420/VA	0.10	mg/L	10.4	----	----	----	----	----
Silver, total	7440-22-4	E420/VA	0.000010	mg/L	0.000067	----	----	----	----	----
Sodium, total	7440-23-5	E420/VA	0.050	mg/L	93.8	----	----	----	----	----
Strontium, total	7440-24-6	E420/VA	0.00020	mg/L	3.18	----	----	----	----	----
Sulfur, total	7704-34-9	E420/VA	0.50	mg/L	34.1	----	----	----	----	----
Tellurium, total	13494-80-9	E420/VA	0.00020	mg/L	<0.00020	----	----	----	----	----
Thallium, total	7440-28-0	E420/VA	0.000010	mg/L	<0.000010	----	----	----	----	----
Thorium, total	7440-29-1	E420/VA	0.00010	mg/L	<0.00010	----	----	----	----	----
Tin, total	7440-31-5	E420/VA	0.00010	mg/L	<0.00010	----	----	----	----	----
Titanium, total	7440-32-6	E420/VA	0.00030	mg/L	<0.00030	----	----	----	----	----
Tungsten, total	7440-33-7	E420/VA	0.00010	mg/L	<0.00010	----	----	----	----	----
Uranium, total	7440-61-1	E420/VA	0.000010	mg/L	0.00479	----	----	----	----	----
Vanadium, total	7440-62-2	E420/VA	0.00050	mg/L	0.00277	----	----	----	----	----
Zinc, total	7440-66-6	E420/VA	0.0030	mg/L	<0.0030	----	----	----	----	----
Zirconium, total	7440-67-7	E420/VA	0.00020	mg/L	<0.00020	----	----	----	----	----

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Appendix C: Cariboo Regional District Water System Statistics

Cariboo Regional District Water System Statistics

2025: CARIBOO REGIONAL DISTRICT WATER UTILITIES			
Water System Name	Active Service Connections	Estimated Per Capita Use (litres per person per day)	Total Demand (m3)
Gateway	27	301.3180386	6899.9
Lexington	29	570.5000027	12942.3
Benjamin	40	86.57475454	2945.1
Canim Lake	43	273.6718044	10008
Alexis Creek	184	274.5882662	30910.4
Russet Bluff	109	n/a	3289.3
Forest Grove	109	300.7652182	27378.9
Horse Lake	143	141.3380904	17663.4
103 Mile	158	267.2187695	36808
LLH	233	399.4421534	82616.4
108 Mile	1455	289.5464075	363369


CRD OPERATOR EOCP CERTIFICATION				
Certification EOCP	Operator	Region	Water Distribution Level	Water Treatment Level
6711	Tyler Olsen	North Cariboo		
1001148	Philip Wilkins	North Cariboo	2	1
8390	Ken Heidema	Central Cariboo	2	
1000182	Charles Howes	Central Cariboo	1	
8482	Jourdy Oullette	South Cariboo	3	2
1001817	Larry Perry	South Cariboo	1	2
1002392	Colin Brusic	South Cariboo		

TOTAL WATER DEMAND BY SYSTEM WITH HIGHEST AND LOWEST USE MONTH AND % VARIATION (CUBIC METRES)												
High/Low Month	June /Dec	Aug /Nov	July /Nov	July /Nov	Aug /Nov	Jan /Nov *	Sept /Feb	July/Feb	Sept/Feb	July/Mar	Aug/Jan	
	Benjamin	Lexington	Russet Bluff	Alexis Creek	LLH	103	108	Horse Lake	Forest Grove	Canlin	Gateway	
High	619	2669.2	7213	5140.4	11089.2	2832	45539	1905.7	3075.5	1159	842.8	Total/Avg
Low	304	331.4	1519	2382.2	3836.3	1748	20637	790.4	1737.3	524	424.6	630464.5
Difference	315	2337.8	5694	2758.2	7252.9	1084	24902	1115.3	1338.2	635	418.2	292%
Total Use	5186	13448.2	31786	44452.7	74697.1	36804	363369	16435	27378.6	10008	6899.9	630464.5
High to Low %	204%	805%	475%	216%	289%	162%	221%	241%	177%	221%	198%	292%

* No leak: July


Cariboo Regional District Water Systems Size Comparison

(by number of active connections)



Cariboo Regional District Water Systems Size Comparison

(by volume demand)



Appendix D: Emergency Response Plan

2026 Cariboo Regional District

Emergency Response & Contingency Plan

108 Mile Water System

*Utilities, Communications, and Emergency Operations Departments
1-1-2026*

By Kelly McDonald, Cheryl McMullen, Kat Chatten, Jourdy Ouellette, Larry Perry and Colin Brusic

Contents

SECTION 1: Emergency Plan Goals	1
1.1 Resiliency in Operations	1
1.1.1. Emergency Response Plan	1
1.1.2. Regional Agency Coordination	1
1.1.3. Mutual Aid Agreements	1
1.1.4. Emergency Power	2
1.1.5. Ability to Meet Water Demands	2
1.1.6. Critical Parts Inventory	2
1.1.7. Critical Staff Resiliency	2
SECTION 2: How to Use This Plan	2
SECTION 3: Emergency Planning Definitions	2
SECTION 4: Emergency Scenarios	3
4.1. Introduction	3
4.2. Emergency Scenario Format	3
4.2.1. Description of Emergency:	3
4.2.2. Indicators	3
4.2.3. Actions	3
4.2.4. Contacts	3
4.2.5. Event Record	3
SECTION 5: Water Supply Contamination	4
5.1. Potential Causes	4
5.1.1. Chemical Spill	4
5.1.2. Flood Event	4
5.1.3. Confirmed Cross Connection	4
5.1.4. System Breach	4
5.1.5. Positive Sample Result	4

108 Mile Water System – 2026 Emergency Response and Contingency Plan

5.1.6. Vandalism	4
SECTION 6: Supply Disruption.....	5
6.1. Equipment Failure.....	5
6.2. Supply Main Break	6
6.3. Extended Loss of BC Hydro Power Supply	8
6.4. Operator Transportation Routes Compromised.....	8
6.4.1. Potential Causes.....	8
7. SECTION 7: Cyber Incident.....	9
8. SECTION 8: Drought.....	9
8.1 Introduction.....	9
Appendix A: Contacts	10
Appendix B: Charts	11
Water Main Break	12
Critical Parts Inventory	12
Appendix C: Drought Management Plan.....	13
Priority Users.....	14
Water Restrictions and Conservation Measures.....	14
Communication Plan	15
Supplemental or Alternate Sources of Potable Water	17
Operational Procedures.....	17
Appendix D: Templates	18
Section Status Report (EOC 401A).....	19
Position Log (EOC 414)	20
EOC Situation Report (EOC 501).....	22
Action Plan (EOC 502).....	25
Incident Report (EOC 550)	27
Rapid Damage Assessment Form.....	29
Appendix E: Communications Templates	30

SECTION 1: Emergency Plan Goals

The Objective of the Cariboo Regional District (CRD) Emergency Response and Contingency Plan (ERCP) is to provide staff and regulatory agencies with a guideline for potential water utility related emergencies.

This Emergency Response and Contingency Plan (ERCP) serves as a guideline to address various emergency situations, recognizing that no two emergencies are exactly alike. Each emergency is described with a general sequence of steps to follow, providing both a structured approach to response and a consistent method for documenting actions taken. Task lists within each emergency section also function as checklists to remind staff of critical items to consider and complete during an emergency. This ERCP includes specific protocols and considerations for the CRD water supply system.

This plan has been prepared to guide the Cariboo Regional District to respond to an emergency arising in the operation of the 108 Mile Water System. The purpose of the ERCP is to:

- ✓ Ensure staff and the public's safety in carrying out emergency tasks.
- ✓ Provide the earliest and safest response to an emergency condition.
- ✓ Ensure that water quality and public health are not compromised.
- ✓ Ensure that water for firefighting is available.
- ✓ Restore normal water system operation.
- ✓ Protect the natural environment from impacts associated with the system operation in the event of an emergency.
- ✓ Contain property damage.

1.1 Resiliency in Operations

Operational resiliency refers to the capability of an operation to adjust, adapt, and maintain service delivery under emergency conditions. The objective for the CRD Water Utility is to achieve high operational resiliency. Indicators of operational resiliency include the following:

- 1.1.1. **Emergency Response Plan:** A comprehensive ERP is essential in building resilience within operations, providing structured guidance for handling emergencies effectively. This document is an integral part of that resiliency framework.
- 1.1.2. **Regional Agency Coordination:** The ERCP must be shared with regional emergency response agencies, ensuring cohesive support. The CRD Emergency Operations Department serves as the local staging agency for the Provincial Emergency Program.
- 1.1.3. **Mutual Aid Agreements:** In certain emergencies, the CRD may need support from neighboring water utilities. 100 Mile House and Williams Lake are two nearby utilities

from which the CRD may seek assistance in the future. The CRD is working toward a formal mutual aid agreement based on community protection principles.

- 1.1.4. **Emergency Power:** The 108 Mile Water System can operate on gravity-fed supply and has backup power generation to maintain disinfection if the power grid fails.
- 1.1.5. **Ability to Meet Water Demands:** With substantial capacity, this CRD water system could, in extreme emergencies, extend its services beyond its current area to assist other communities.
- 1.1.6. **Critical Parts Inventory:** Appendix B provides a list of critical parts and their availability. Appendix A includes contact names for Cariboo support agencies offering specialized parts or services.
- 1.1.7. **Critical Staff Resiliency:** Staff's ability to respond and remain calm during extreme events is only evident when tested. Training and reinforcement of sound decision-making at all levels will support preparedness for emergency situations.

SECTION 2: How to Use This Plan

The Water System Emergency Response and Contingency Plan (ERCP) is a guide for handling water system emergencies. The “Actions” section outlines various potential emergencies and provides steps to help minimize further damage.

After an emergency, the CRD will complete a Post Incident Report (see Appendix D). Regular review exercises and updates will strengthen our emergency response capabilities. We ask all plan holders to participate and offer recommendations to continually improve the ERCP.

Remember, the ERCP is only effective if everyone reviews, understands, and contributes to its ongoing development.

SECTION 3: Emergency Planning Definitions

This section provides emergency planning definitions used in this document, following *AWWA Manual 19: Emergency Planning for Water Utilities*.

Emergency: An unexpected event that may compromise water quality or reduce the availability of domestic, irrigation, or fire flow water for the community.

Minor Emergency: A localized, routine incident impacting a small number of customers, such as a small pipe break, vehicle collision with a hydrant, brief power outage, or minor service repair. Minor emergencies should be manageable without special resources and, if effectively handled, can be prevented from escalating into major emergencies.

Major Emergency: A significant event affecting a large portion of the water system, posing risks to water quality or quantity and potentially endangering community health and safety. Major emergencies are rare but impactful.

Natural Disaster: Events caused by natural forces beyond human control, including wildfires, earthquakes, floods, tornadoes, heat domes, freezing, and other severe weather-related incidents.

Human-Caused Disaster: Disasters resulting from human actions, whether accidental or intentional. These may include human error, accidents, labor disputes, negligence, vandalism, sabotage, terrorism, biological contamination, or chemical spills.

Hazard: A source of potential harm or danger linked to a disaster, such as unstable slopes from a creek wash-out or ground shaking from an earthquake.

Lifeline Supply: Essential community services that support health, safety, and sustenance. Lifeline utilities include water, wastewater, electricity, and natural gas, as well as critical transportation, communication, healthcare, and emergency operations centres.

SECTION 4: Emergency Scenarios

4.1. Introduction

Sections 5 and 6 list potential water system emergencies related to the physical components of the water supply. Section 7 describes the steps for a cyber threat or vandalism.

4.2. Emergency Scenario Format

Each emergency scenario in this ERCP follows a consistent format:

- 4.2.1. **Description of Emergency:** Describes each potential emergency for easy reference. Sections 5 and 6 cover physical water service issues, while Section 7 addresses cyber incidents and vandalism.
- 4.2.2. **Indicators:** Outlines how each emergency can be recognized, either by CRD staff or external contacts.
- 4.2.3. **Actions:** Lists response steps for CRD staff, generally in recommended order. This list serves as a guideline, and the lead Water Operator can use the provided checklist to verify all necessary actions are taken.
- 4.2.4. **Contacts:** Lists relevant contact agencies; specific contacts are found in the ERCP's Communications Section.
- 4.2.5. **Event Record:** A checklist at the page bottom summarizes the event, records whether photos were taken, and tracks emergency reporting.

All events, including minor repairs and leaks, should be documented and sent to the CRD Office for electronic filing. Each event should be recorded by date. Large events should have dedicated folders containing photos and data, following a standardized naming protocol.

SECTION 5: Water Supply Contamination

Description of Emergency: Contamination has been detected or possible contamination is present.

Indicators: Public notification (taste, odour or colour observations), poor water sample results, visible observations made by Water Operators, cross connection with potential contamination.

5.1. Potential Causes

- 5.1.1. Chemical Spill (e.g. transport truck, industry)
- 5.1.2. Flood Event
- 5.1.3. Confirmed Cross Connection
- 5.1.4. System Breach (e.g. water main break) *see 6.2.
- 5.1.5. Positive Sample Result (e.g. E. coli or other immediate threat to public health contaminant)
- 5.1.6. Vandalism

Actions:

- 1) Notify Water Operator.
- 2) Notify Drinking Water Officer (DWO).
- 3) Assess threat level (see Appendix B).
- 4) Notify Communications Department.
- 5) Water Operators to investigate site and inform Manager of Utilities of possible situation. Manager to contact Interior Health.
- 6) Confirm that the source of contaminant is mitigated.
- 7) If chemical contamination confirmed or highly suspected to be present:
 - a) Attempt to isolate.
 - b) Discuss with Engineer, Biologist/Chemist (Lab) and DWO to develop a reasonable and representative sampling program.
 - c) Contact Lab and arrange bottles if required and collect samples for rush analysis.

- 8) Report any spills to the Provincial Agency responsible (see Appendix A).
- 9) In an extreme situation of contamination, consider shutting down all supply pumps.
 - a) Pump stations would shut off and “Do Not Use” notices would be provided to the public. CRD senior management would make this call.
- 10) Communication: Begin public notification if required and follow Water Quality Notification Procedures.
- 11) Continue discussion with appropriate experts for moving forward.
- 12) Discussions to consider alternate water source if needed. Involve Emergency Operations Department and Notify Fire Department.
- 13) Continue monitoring until water quality is back to normal and IH gives approval to lift advisory or notice.
- 14) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.
 - d) After action report.

SECTION 6: Supply Disruption

6.1. Equipment Failure

Description of Emergency: This type of emergency is typically caused by extreme weather events that place a very high demand on the Water Treatment Plant, or any other situation where water demands are high, and equipment or infrastructure reduces the ability to maintain maximum output.

Indicators: Visual observations by Water Operators. Failure of equipment as identified by SCADA and alarms.

Actions:

- 1) Document Situation: Note date, time, location and means of event recognition.
- 2) Notify Water Operator.
- 3) Notify Manager.
- 4) Notify Communications Department.

- 5) If cause is identified as a main break, see section 6.2.
- 6) WTP Site Investigation: Generally, this problem is caused by high flows and overheating VFD's.
- 7) Check control room raw water pump temperatures on variable frequency drive (VFD) displays.
- 8) Check all SCADA pages and trends to determine what is operational, what has failed, or what is at risk of failure in the WTP.
- 9) Check on alarms.
- 10) Note status of chlorine disinfection, reservoir levels, source pump status, chemical dosing status, and raw water flows.
- 11) Check all necessary WTP equipment to confirm proper functionality.
- 12) Switch – Adjust Equipment: The WTP has built in redundancy on certain critical pieces of equipment such as mixers, dosing pumps, raw water pumps, chlorine supply pumps, and has a spare parts inventory for other critical pieces of equipment.
- 13) Check WTP shelving and inventory lists for parts that may be available to aid in necessary repairs. If necessary, contact 100 Mile House Public Works for assistance (same Treatment Plant).
- 14) If the issue stems from the VFD's, alternate pumps. Call contract electrician if necessary.
- 15) If issue is due to drawdown in Supply Wells, consult **Drought Management Plan (Appendix C)** and proceed to next step.
- 16) If problem persists:
 - ✓ Communicate with Interior Health, issue an advisory as recommended (see Section 1).
 - ✓ Implement emergency water restrictions (Communications Department).
 - ✓ Contact 108 Volunteer Fire Department and inform them of situation.
- 17) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.

6.2. Supply Main Break

Description of Emergency: Failure or damage to a water supply main causing loss of water and/or pressure.

Indicators: SCADA alarms indicating pressure loss, calls from residents or staff observations.

Actions: Steps to be taken by CRD staff:

- 1) Contact Manager of Utilities.
- 2) Contact Water Operator.
- 3) Determine location.
- 4) Stop the flow of water by closing valves and isolating the break, depending on the scale of the break (see chart in Appendix B); attempt to maintain positive pressure.
- 5) Contact Manager and describe the emergency.
- 6) Determine what section of the system has been affected by the depressurization.
- 7) If there is a potential that the system has been contaminated, the Manager of Utilities will contact Interior Health for recommendations on issuing a Water Advisory. See Appendix E (follow Communications procedures).
- 8) Make the site safe by implementing traffic control: block road, if necessary, contact traffic control contractor (Appendix A).
- 9) If possible, mitigate danger to the public and further damage of infrastructure or property. If necessary and feasible, set up sediment control measures and de-chlorinated water released.
- 10) Assess immediate damage.
- 11) Coordinate repair plans with appropriate contractors (see Appendix A).
- 12) Contact the Provincial Agency responsible (see Appendix A) for large discharges of chlorinated water including;
- 13) If there is significant sediment or chlorinated water in streams.
- 14) Call Fire Department to inform them when hydrants are in or out of service.
- 15) Complete documentation:
 - a) Record of events, include times and dates.
 - b) Complete a comprehensive damage assessment.
 - c) Investigate potential causes.
 - d) After action report.

6.3. Extended Loss of BC Hydro Power Supply

Description of Emergency: The loss of power will stop the pumping systems to supply water to the distribution system and from filling the reservoir if back up power generator fails.

Indicators: SCADA alarms

Actions:

- 1) Maintain fuel supply to generators.
- 2) Change system settings if necessary to keep reservoirs topped up.
- 3) If sudden phase loss or total power loss causes equipment failure see Section 6.
- 4) If issues with power supply persist:
 - ✓ Contact BC Hydro for information on the timelines for power restoration.
 - ✓ Communicate with Interior Health, issue an advisory as recommended (see Section 1).
 - ✓ Implement emergency water restrictions (Communications Department).
 - ✓ Potentially throttle down the pressure within the distribution to reduce water loss (always above 20 psi).
 - ✓ Contact 108 Volunteer Fire Department and inform them of situation.

6.4. Operator Transportation Routes Compromised

6.4.1. Potential Causes

- Forest fire
- Accident
- Mechanical issues with vehicle
- Construction

Description of Emergency: The usual transportation route to the 108 Mile area is blocked (e.g., by a forest fire or accident), and no operator can be onsite to perform duties.

Actions:

- 1) Contact Manager of Utilities.
- 2) Manager will inform Interior Health Officer of situation.
- 3) Continue to monitor system using SCADA.

4) If issue persists:

- ✓ Contact 100 Mile House Public Works for assistance.
- ✓ Reach out to local contact if physical checks are needed. Preferably local contractor with system experience (see Appendix A).
- ✓ Contact the Communications Department to issue applicable advisories (at the recommendation of Interior Health).

5) Complete documentation:

- a) Record of events, include times and dates.
- b) Complete a comprehensive damage assessment.
- c) Investigate potential causes.

7. SECTION 7: Cyber Incident

(Omitted for security reasons.)

8. SECTION 8: Drought

8.1 Introduction

Drought is often caused by a long duration of inadequate rainfall or snowmelt to replenish the level of the water source. It can also be the result of a breakdown in a crucial piece of a water system's infrastructure; or a prolonged issue with water quality that prevents the supply of potable water for an extended period. All of these circumstances can result in a significant depletion in the source capacity or even a complete loss of source. The Cariboo Regional District's Drought Management Plan for the 108 Mile Water System serves as a guide to monitoring, managing and conserving water use in the event of an impending drought. The objectives of this Plan are to:

- 1) Identify the priority users of the water supply.
- 2) Provide direction on water conservation before and during the drought period.
- 3) Establish a guideline for communicating issues and instructions to users and other key contacts.
- 4) List supplemental or alternate sources of potable water in the event of a prolonged drought.

Appendix C outlines the Cariboo Regional District's Drought Management Plan.

Appendix A: Contacts

(Omitted for security reasons)

Appendix B: Charts

Water Main Break

<i>Water Main Break Severity Chart</i>				
<i>Class 1</i>	<i>Class 2</i>	<i>Class 3</i>	<i>Class 4</i>	<i>Class 5</i>
<i>Routine</i>	<i>Minor</i>	<i>Substantial</i>	<i>Major</i>	<i>Catastrophic</i>
Small enough to leave until repairs are convenient	Water Pooling	Isolation Needed	Large area needs to be isolated	Complete Distribution System Shut down
Positive Pressure Maintained	Positive Pressure Maintained	Positive Pressure may not be possible	Loss of Pressure in large area of distribution system	Complete system pressure loss (e.g. drained reservoir)
Consult with DWO if any concerns.	Advisory may be required, consult with DWO.	Advisory Needed, contact Interior Health. Assess damage.	Advisory needed, contact interior health. Assess damage	Advisory needed, contact interior Health. initiate EOC.
Flush line (localized)	sample for bacteriological contamination after flushing lines as per C651-14 (localized)	Sample for bacteriological contamination after flushing lines as per AWWA C651-14	Chemical and bacteriological sampling may be needed. Possible unidirectional flushing and super chlorination needed as per AWWA C651-14	Chemical and bacteriological sampling needed at various points in the system. System wide flushing needed. Super chlorination required as per AWWA C651-14

Critical Parts Inventory

<i>Critical Parts Inventory</i>							
Part	Use	Location Stored	Vendor	Part	Use	Location Stored	Vendor

Appendix C: Drought Management Plan

DROUGHT MANAGEMENT PLAN

Priority Users

The area served by the 108 Mile Water System is comprised mainly of residents, and also includes a gas station, small shopping mall, fire hall, golf resort, church, community hall, elementary school, park, an airport and 3 restaurants/coffee shops. In a drought situation, the provision of water will be prioritized as follows:

Priority Level	User	Comments
1	Residents	The CRD is obligated to provide water to the residents served by the 108 Mile Water System for basic health and sanitation needs. The Water Sustainability Act states that the maximum requirement per household per day for those purposes is 250 litres.
2	108 Mile Volunteer Fire Dept.	The risk of fire greatly increases during a drought and a supply of water must be maintained for fire protection purposes.
3	Elementary School	Water is required for sanitation purposes. The washrooms in the school require water for the flushing of toilets and washing of hands by children and staff.
4	All Other Businesses and Organizations (these may need to be further prioritized following public meeting discussions)	Businesses that rely on the provision of water may be required to reduce hours of operation or close down temporarily during a drought in order to conserve water. However, a prolonged drought may result in a significant loss of revenue, which would need to be addressed.
5	Public Park	Outdoor taps would need to be shut down during a drought.

Water Restrictions and Conservation Measures

The following restrictions will be imposed and conservation measures recommended to 108 Mile Water System users at various stages prior to and during a drought:

STAGE 1: PREPAREDNESS	
Permitted Uses	Restrictions
Drinking water Bathing Handwashing dishes or using dishwasher Washing machine Watering plants with a hose or watering can Bathing pets. Washing vehicles.	May 1 to Oct. 1: Lawn watering on reduced days for reduced hours, per bylaws.
	Conservation Measures Install water-saving devices.
STAGE 2: IMPENDING DROUGHT – CONSERVATION	
Permitted Uses	Restrictions
Drinking water Bathing Handwashing dishes or using dishwasher Washing machine Watering plants with a hose or watering can	Lawn watering days and hours restricted further. Wash vehicles only if absolutely necessary.
	Conservation Measures Bathe pets only as needed. Use washing machine for full loads only. Use dishwasher for full loads only.

108 Mile Water System – 2026 Emergency Response and Contingency Plan

STAGE 3: DROUGHT – RESTRICTIONS	
Permitted Uses	Restrictions
Drinking water (all users) Bathing Handwashing dishes or using dishwasher Washing machine	No watering of lawns or watering of plants, per bylaws. No bathing of pets unless absolutely necessary. No washing of vehicles. No filling of swimming pools. No power-washing.
	Conservation Measures
	Bathe only as needed and/or reduce time in shower. Use washing machine for full loads only. Use dishwasher for full loads only.

Communication Plan

Communication between the CRD and users of the 108 Mile Water System, as well as with key operational contacts, is imperative during an emergency situation. Providing timely and clear information and instructions greatly reduces confusion, frustration and anxiety, and enables outside agencies to provide assistance more effectively if needed.

STAGE 1: PREPAREDNESS		
Water use is routinely higher from mid-Spring to the end of Summer each year due to less rainfall, increased lawn and garden maintenance, swimming pools, more frequent car-washing and showers, etc. Water levels are constantly monitored, and watering restrictions are put in place annually from May 1 to October 1 as a preventative measure to minimize depletion of the water supply during these months.		
Procedures (Concurrent)		Target
Finance Dept. mails notice of water restrictions and water conservation recommendations with annual utility bills in April of each year.		Residents
Communications Dept. posts notice of water restrictions and water conservation recommendations on website and social media.		All users of the 108 Mile Water System
Communications Dept. sends notice of water restrictions and water conservation recommendations by email.		Subscribed users.
Water Operators post notice of water restrictions and water conservation recommendations on bulletin boards at 108 Mall, gas station, mailboxes		Users of the 108 Mile Water System who don't have access to a computer.
STAGE 2: POTENTIAL THREAT – DIMINISHED WATER SUPPLY		
If there is little snowmelt in the Spring and rainfall in the Spring/Summer is not enough to bring the source of the water supply to an adequate level, further restrictions on water use may be required. Prolonged water quality issues may result in having to obtain water from an alternate source until rectified. Any significant or ongoing issues would indicate that action is required to prevent the possibility of a water supply crisis.		
Procedures		Target
1.	Inform key contacts of possible threat to water source: Water Operators notify Manager of Utilities Manager of Utilities informs other key contacts	Manager of Utilities Drinking Water Officer Electoral Area Director Manager of Fire Administration

108 Mile Water System – 2026 Emergency Response and Contingency Plan

2.	At Interior Health's direction, Manager of Utilities and Communications Dept. have public notice mailed to users, posted on website, social media, and on local bulletin boards.	All users of the 108 Mile Water System
	Communications Dept. sends public notice by email.	Subscribed users
3.	Manager of Utilities notifies CRD Managers involved in Emergency Planning as a precautionary measure.	Chief Administrative Officer Manager of Communications Manager of Emergency Programs
4.	Manager of Utilities, Water Operators and Electoral Area Director hold public meeting to discuss potential drought, further restrictions required and recommended conservation measures.	All users of the 108 Mile Water System
5.	Manager of Utilities notifies other agencies as a precautionary measure that assistance may be required if situation can't be rectified.	District of 100 Mile Ministry of Water, Land and Resource Stewardship Ministry of Emergency Management and Climate Readiness
STAGE 3: EMERGENCY – SIGNIFICANT DEPLETION OR LACK OF SOURCE		
The following situations are considered critical: • An inability to keep the water supply at a level that will provide enough water to meet the basic health and sanitation needs of the users. • A prolonged issue with the water system infrastructure that results in the inability to provide water to the users. • A severe or prolonged water quality issue that cannot be easily rectified. • The inability to provide an adequate water supply for fire protection. • An ongoing water supply issue that results in significant losses for businesses in the service area.		
Procedures		Target
1.	Inform key contacts of crisis situation. Discuss further steps: Water Operators inform Manager of Utilities. Manager of Utilities notifies other key contacts.	Manager of Utilities Drinking Water Officer Electoral Area Director Chief Administrative Officer Manager of Fire Administration Manager of Communications Manager of Emergency Programs
2.	At Interior Health's direction, Manager of Utilities and Communications Dept. have public notice mailed to users, and posted on website, social media, and local bulletin boards.	All users of the 108 Mile Water System
	Communications Dept. sends notice of emergency situation by email and via Voyent Alert.	Subscribed users
3.	Manager of Utilities and Communications Dept. post notice in local newspaper; make radio announcements.	All users of the 108 Mile Water System
4.	Manager of Utilities, Water Operators and Electoral Area Director hold public meeting to discuss further steps.	All users of the 108 Mile Water System
5.	Manager of Utilities notifies other agencies. Discuss what assistance may be available.	District of 100 Mile Ministry of Water, Land and Resource Stewardship Ministry of Emergency Management and Climate Readiness

Supplemental or Alternate Sources of Potable Water

Supplemental or Alternate Source	Contact Information	Capacity Available	Estimated Time To Deliver	Estimated Cost
Backup Water Source				
Reservoir Rental Company				
Bulk Haul Water	District of 100 Mile 250-395-2434 Bulk Water Station is just off Exeter Truck Route near Co-Op Cardlock Triple P Sanitation (upon verification of IH permit) Canim Lake Bulk Water Station (scheduled to open in 2026)	Not specified Not specified TBD	Pick up only Self Serve	\$100 upon opening a/c, plus \$0.02 per litre. TBD
Other Water Supplier	Triple P Sanitation (upon verification of IH permit)	Not specified		
Bottled Water	Cariboo Water Purification Centre Cool Clear Water Williams Lake Water Factory	Not specified Not specified Not specified	 Tuesdays	 \$6.50 / 5 Gal \$4.00 / 3 Gal

Operational Procedures

Action		Person Responsible
1	Ensure pump is shut off (to protect pump).	Water Operator
2	Notify all users by social media, email distribution, radio and public bulletins. High risk users to be notified by telephone call. Situationally assessed for best means of communication process.	Manager of Utilities Manager of Communications
3	Contact government agencies (see below) for advice and assistance.	Manager of Utilities
4	Arrange alternate source (e.g. bottled water, bulk hauler and storage tank).	Manager of Utilities
Government Agency Contacts: • Drinking Water Officer • Local government's Emergency Program Coordinator • Ministry of Forests, Lands and Natural Resource Operations • Others as necessary, depending on severity (ie. Fire Department)		

Appendix D: Templates

Section Status Report (EOC 401A)



Section Status Report


EOC 401A



INCIDENT NAME		TASK NUMBER	ICS SECTION
DATE PREPARED		TIME PREPARED	

1. CURRENT SITUATION <i>(What is occurring now within your area of responsibility?)</i>
2. OUTSTANDING ISSUES/CHALLENGES <i>(What issues within the current operational period still need to be resolved?)</i>
3. ANTICIPATED PRIORITIES/ACTIVITIES <i>(What will the priorities be for the next operational period?)</i>
4. DISTRIBUTION LIST / DISPOSITION
☐ Status Reports are to be completed by 14:00, for Planning Section to use to inform the SitRep and Action Plan for the next operational period
COMPLETED BY

Name (Print): _____ Position: _____ Signature: _____ ☐



Page 1 of 2

108 Mile Water System – 2026 Emergency Response and Contingency Plan

INCIDENT NAME []		TASK NUMBER []	DATE PREPARED []
NAME []		ICS SECTION []	ICS POSITION/UNIT []
ACTIVITY LOG			
Time	Action/Decision/Enquiry		Action Required
[]	[]		[]
[]	[]		[]

Use **highlighter** to identify issues that should be tracked through multiple operational periods.

Page 2 of 2

EOC Situation Report (EOC 501)



EOC Situation Report

Cariboo Regional District

EOC 501

The purpose of this form is to summarize new and ongoing details of the emergency event

Date of Report:

Time of Report:

Initial Report: ☐ Final Report: ☐

Event Name:

Event Type:

Task #:

Approved by:

EOC Director:

Primary Contact Information
 Phone:
 Email:

Name:
 Function/Title:
 Other:

EOC Activation:	Overall Status:	Incident Prognosis:	Overall Severity:
☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ No EOC	☐ Assistance Required ☐ Under Control ☐ Resolved ☐ Unknown ☐ Closed	☐ Worsening ☐ Stable ☐ Improving ☐ Unknown	☐ Major ☐ Moderate ☐ Minor ☐ Unknown

Situation Summary *(What has happened and/or changed since the last Situation Report? **Bold** new information)*

Current Priority Needs *(Resources/Information/Support)*

Cariboo Regional District
Emergency Program Services
Page 1 of 3

Date of Report:		Time of Report:		Initial Report: ☐	Final Report: ☐
Event Name:		Event Type:		Task #:	

Human Impact *(Cariboo Regional District area/residents – does not include municipalities or indigenous on-reserve)*

**see attached alert & order tracking sheet for additional detail*

Population on Alert:	Population on Order:
---	---

Area under Alert:	Area under Order:
--	--

TOTAL REGIONAL POPULATION <u>AFFECTED</u> (either on alert or order)	Click or tap here to enter text.
--	---

# Evacuated	# Injured	# Homeless	# Missing	# Fatalities	# Hospitalized

Population information is based on the Census population numbers from 2020 and reported 9-1-1 population counts

Public Information and Media Issues

Other Impact *(Agricultural/Animals/Transportation/Utilities/Communications)*

Date of Report:		Time of Report:		Initial Report:	☐	Final Report:	☐
Event Name:		Event Type:		Task #:			

Future Outlook/Planned Actions *(What does the EOC hope to accomplish in the next operational period?)*

Cariboo Regional DistrictEmergency Program ServicesPage 3 of 3

Action Plan (EOC 502)



Action Plan

FOR NEXT OPERATIONAL PERIOD

EOC 502

INCIDENT NAME	TASK NUMBER	ICS SECTION
DATE PREPARED	TIME PREPARED	

OBJECTIVES
List goals (in priority order) which identify what will need to be completed in the next operational period. Use active verbs: acquire, advise, complete, confirm, consult, contact, declare, determine, develop, establish, ensure, gather, identify, issue, notify, obtain, prepare, request, support.

Objective:		
Task	Section	Deadline

Objective:		
Task	Section	Deadline

Objective:		
Task	Section	Deadline

INCIDENT NAME		TASK NUMBER	ICS SECTION
DATE PREPARED		TIME PREPARED	

Objective:			
Task		Section	Deadline

Objective:			
Task		Section	Deadline

Objective:			
Task		Section	Deadline

APPROVALS

Planning Section Chief *(Review, sign and forward to EOC Director)*

Prepared By: _____ **Position:** _____ **Date:** _____ **Time:** _____

EOC Director *(Review, sign and forward to Documentation for copying and distribution)*

Authorized By: _____ **Position:** _____ **Date:** _____ **Time:** _____

Authorizing Signature: _____

Incident Report (EOC 550)

	Incident Report	
<i>The purpose of this form is to capture and share situational awareness information as it becomes known</i>		
When receiving a report – first ask if it is a LIFE SAFETY issue. If so, have the person call 9-1-1. Second, confirm jurisdiction – a ministry, municipality, or another RD may be responsible.		
EVENT _____	DATE: _____	REPORTED BY: _____
EMCR Task No. _____	TIME: _____	RECEIVED BY: _____
TYPE OF INCIDENT _____		
LOCATION _____		
SUMMARY OF INCIDENT <i>(what happened?)</i>		
WHO IS RESPONDING? <i>(involved agencies & actions)</i>		
PLEASE PRINT DOUBLE-SIDED		Page 1 of 2

WHO/WHAT IS AFFECTED?		Damage: <i>(buildings, bridges, roads, utilities, etc.)</i>
People	Estimated Confirmed	
Fatalities		
Injuries		Other Information:
Evacuees		
Homes Evacuated		
SITUATION FORECAST		
Prepared by: _____		Approved by EOC Director: _____
Name and <u>Signature</u>		Name and <u>Signature</u>
PLEASE PRINT DOUBLE-SIDED		Page 2 of 2

Rapid Damage Assessment Form

Rapid Damage Assessment Form				
Inspection Inspector ID: _____ Inspection date: _____ time: _____ (dd MMM yy) (24 hour clock) Agency: _____ Areas inspected: ☐ Exterior Only ☐ Exterior and Interior				
Building Description Building Name: _____ Address: _____ Building contact/phone: _____ Number of stories above ground: _____ below ground: _____ Number of residential units: _____ Type of Construction ☐ Wood Frame ☐ Masonry ☐ Steel Frame ☐ Other: _____ ☐ Concrete Frame Primary Occupancy ☐ Single Family Dwelling ☐ Industrial ☐ School ☐ Multi-residential ☐ Offices ☐ Government ☐ Emergency Services ☐ Commercial ☐ Other: _____				
Evaluation Investigate the building and area around it for the conditions below and check the appropriate column.				
Observed Conditions: Collapse, partial collapse, or building off foundation Building or store leaning / out of plumb Damage to primary structural members, racking of walls Falling hazards such as chimney, parapet, etc. Ground movement or slope failure, scour, erosion Damaged /submerged fixtures or services, (electric / gas) Proximity risks / other (specify): _____ Number of residential units not habitable: _____ Comments: _____ _____ _____	Minor/None	Moderate	Severe	Estimated Building Damage (excluding contents) ☐ None ☐ 1 – 10 % ☐ 11 – 30 % ☐ 31 – 60 % ☐ 61 – 99 % ☐ 100 %
Posting Severe conditions endangering the overall building are grounds for an Unsafe posting. Localised Severe and overall Moderate conditions may allow a Restricted Use posting. Where required, ensure that RESTRICTED USE and UNSAFE placards are posted at all entrances. ☐ INSPECTED (Green Placard) ☐ RESTRICTED USE (Yellow Placard) ☐ UNSAFE (Red Placard) Record any use and entry restrictions exactly as written on placard: ☐ Do not enter or use the following areas: _____ ☐ Brief entry allowed for access to contents: _____ ☐ Do not use flooded/damaged appliances, devices or services (electric, gas) until recertified by a licensed contractor ☐ Other restrictions: _____ _____ _____				
Further Actions Check the boxes below only if further actions are needed. ☐ Barricades needed in the following areas: _____ ☐ Detailed Evaluation recommended ☐ Structural ☐ Geotechnical ☐ Other _____ ☐ Other recommendations: _____ Comments: _____ _____ _____				
Residential and All Structures ☐ Access: _____ _____ ☐ Access to other parts of operation: _____ ☐ Wells / Septic: _____ ☐ Insurance: _____ Comments: _____ _____ _____				

Appendix E: Communications Templates



The Cariboo Regional District has issued a Boil Water Notice to users of the {SYSTEM NAME} Water System, pursuant to a request of a Drinking Water Officer under Section 14 of the *Drinking Water Protection Act*. This Notice remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. This boil water notice is being issued because {REASON}. This notice is being issued {CHOOSE: as a precautionary measure to protect public health. OR in order to protect public health and safety from significant health risks presented by pathogens in the water supply.}

All users of the {WATER SYSTEM NAME} Water System are asked to bring water to a rolling boil for a minimum of one minute before using water from the system for:

- Drinking (or use an alternate, safe source of water)
- Cooking (if not boiled)
- Brushing teeth
- Washing Dishes
- Washing fruits or vegetables to be eaten raw
- Watering animals

Also, please use hand sanitizer after washing hands.

If you have further questions, please call Environmental Services at 1-800-665-1636 during regular office hours.


For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe. Residents can also sign up the Cariboo Chilcotin Emergency Notification System to be notified directly of emergency orders and alerts or utility service interruptions at cariboord.ca/EmergencyNotifications.



cariboord.ca

facebook.com/caribooregion
facebook.com/CRDEmergencyOperations





The Cariboo Regional District has issued a Do Not Use Notice to users of the {SYSTEM NAME} Water System, pursuant to a request of a Drinking Water Officer under Section 14 of the *Drinking Water Protection Act*. This Notice remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Due to the presence of {if known, be specific, or if unknown say "contaminants in the water supply posing an immediate threat to resident's safety"}, the Cariboo Regional District is implementing this until further notice. Follow all instructions below:

All users of the {WATER SYSTEM NAME} Water System are asked to immediately stop using water from the system for any purpose. This includes: drinking, making beverages or ice, brushing teeth, preparing or washing food, bathing, water for animals, washing anything (including vehicles), and watering plants.

Do not turn your taps on for any reason. Boiling water will NOT make it safe! Water from your hot water tank may also be unsafe, and you are advised to consult a qualified plumber before draining the tank.

The Cariboo Regional District has contacted Interior Health and the Ministry of Environment to request their cooperation in investigating this matter. In addition, the Cariboo Regional District is taking immediate action to find another source of water supply for residents of {WATER SYSTEM NAME}.

During this time, an alternate water source will be available at {ADDRESS AND OPERATING HOURS}.

If you have further questions, please call Environmental Services at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notice-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe. Residents can also sign up the Cariboo Chilcotin Emergency Notification System to be notified directly of emergency orders and alerts or utility service interruptions at cariboord.ca/EmergencyNotifications.




cariboord.ca

facebook.com/caribooregion
facebook.com/CRDEmergencyOperations





PUBLIC NOTICE



WATER QUALITY ADVISORY

{SYSTEM NAME} Water System
Effective {DATE}

The Cariboo Regional District has issued a water quality advisory, to the {SYSTEM NAME} Water System users because of {issue} levels exceeding the *Guidelines for Canadian Drinking Water Quality*. This Advisory remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Health Canada's Guidelines for Drinking Water has established a maximum acceptable concentration (MAC) for {issue} in drinking water of {standard}. Recent water samples submitted show {issue} concentrations that exceed the MAC.

Add information provided by Health Canada or Interior Health about the nature of the water quality advisory. This section requires approval from a Drinking Water Officer.

{Other safety instructions or advisories. I.e. is the water safe for other non-consumption purposes, how does boiling water impact it, etc.}

If you have further questions, please call the Environmental Services department at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant

 @CaribooRD


cariboord.ca

facebook.com/caribooregion

 facebook.com/CRDEmergencyOperations



PUBLIC NOTICE



WATER QUALITY ADVISORY

{SYSTEM NAME} Water System
Effective {DATE}

The Cariboo Regional District has issued a water quality advisory, to the {SYSTEM NAME} Water System users because of manganese (Mn) levels exceeding the *Guidelines for Canadian Drinking Water Quality*. This Advisory remains in effect until further notice.

The Cariboo Regional District's water systems are tested regularly to ensure they meet public health regulations. Health Canada has established a maximum acceptable concentration (MAC) for manganese in drinking water of 0.12 mg/L. Recent water samples submitted show manganese concentrations that exceed the MAC.

Manganese (Mn) is an element found in air, food, soil and drinking water. While a small amount of Mn is essential for human health, new Health Canada research has shown drinking water with too much Mn can be a risk to health for infants and young children.

Infants and young children are the most sensitive and vulnerable population, as their bodies absorb more manganese and cannot regulate or remove the chemical as readily as adults and older children. As a result, the **drinking water from this system must not be used to prepare formula for bottle-fed infants**. An alternate source of safe drinking water, such as bottled water, must be used when preparing formula for infants and young children. **Boiling the water will not lower the manganese level.**

Breastfed infants are generally considered at lower risk to manganese exposure as the transfer of manganese to breast milk is limited. Pregnant or breastfeeding women who have concerns may wish to use a safe, alternate source of drinking water or consult with a healthcare professional.

Water exceeding the MAC for manganese can be used for cooking and drinking by non-vulnerable groups and is still considered safe for hand washing, bathing and showering. If you have further questions, please call the Environmental Services department at 1-800-665-1636 during regular office hours.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notices-and-advisories. To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe.

 @CaribooRD

 cariboord.ca

 facebook.com/caribooregion
facebook.com/CRDEmergencyOperations



The Cariboo Regional District has issued a water quality advisory for users of the Forest Grove Water System because of a positive test result for low coliform found in the system.

For this reason, as precautionary measure, any high-risk users, including those with weakened immune systems, young children and those on dialysis are advised to:

- use purchased bottled water or boiled water for drinking, brushing teeth, dishwashing, preparing food, and making ice, or
- bring water to a rolling boil for one minute, then cool to an appropriate temperature before using.

The CRD regularly tests the water system as part of its Water Quality Monitoring Program. The advisory will remain in effect until further notice. We apologize in advance for any inconvenience this may cause.

When satisfactory results are reported from the required testing, customers will be notified that the advisory has been lifted. If you have questions, please call the Environmental Services department at 1-800-665-1636. If calling outside of regular business hours (8:30 a.m. to 4:30 p.m. Monday to Friday), please dial "5" when prompted to reach our emergency after hours contact.

For more information about boil water advisories and service interruptions in the CRD and what to expect, visit cariboord.ca/water-notice-and-advisories.

To receive updates on CRD water systems and other relevant information within the CRD, residents are reminded to subscribe to the latest news on our website at cariboord.ca/subscribe.

