ADDENDUM NO. 3

RFQ TOTR2026 PW-09
Garden of the Gulf Museum Accessible Washroom & Ramp Project
Issued By: Town of Three Rivers
Date Issued: November 17, 2026

1. Closing Date Extension
The closing date for RFQ TOTR2026 PW-09 is hereby extended.
Previous Closing Date:
November 26, 2026 at 2:00 PM (Atlantic Time)
Revised Closing Date:
December 3, 2026 at 2:00 PM (Atlantic Time)
All quotations must be submitted no later than the revised closing date and time indicated above.

2. Clarification – Domestic Water Service Piping
The following clarification is issued regarding the domestic water service piping shown in the tender documents:
Water Piping
Refer to Note 4 on the drawings and Sections 3.2.3 and 3.2.4 of the specifications.

- Section 3.2.3 permits either copper or PEX piping for above-ground installations.
- Section 3.2.4 specifies PEX piping for underground installations.
- The project specifications already provide for the use of PEX piping and no change to the specified materials is required.

Clarification: References to copper water service piping shown on the civil drawings were included in error. The project shall be constructed in accordance with the specifications, which permit copper or PEX above ground and require PEX for all underground water service piping.

3. General
This Addendum forms part of the Contract Documents and shall be acknowledged by all proponents in their submission. All other terms, conditions, specifications, and requirements remain unchanged.

Proponent Acknowledgement
I/We acknowledge receipt of Addendum No. 1, No.2, and No. 3 and have included their requirements in our quotation.
Company Name: _____
Authorized Representative: _____
Signature: _____
Date: _____